

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF BRACKEN COUNTY	)	
WATER DISTRICT NO. 1 FOR DEVIATION	)	CASE NO.
FROM THE REQUIREMENTS FOR WATER	)	94-507
STORAGE	)	

O R D E R

By letter filed on December 5, 1994, Bracken County Water District No. 1 ("Bracken Water") requested a time extension to comply with Commission Regulation 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. On June 11, 1991, the Commission ordered Bracken Water to bring its water storage facilities into compliance with Commission regulations by July 1, 1994.<sup>1</sup> On April 20, 1994, the Commission granted Bracken Water a time extension until December 31, 1994 to comply with Commission Regulation 807 KAR 5:066, Section 4(4).

On December 5, 1994, Bracken Water informed the Commission that it has been actively pursuing methods for complying with the Commission's regulations. In that regard, Bracken Water's engineering consultant has prepared construction plans and

---

<sup>1</sup> Case No. 91-112, The Application of Bracken County Water District #1 for Approval of a Deviation from the Requirements of Testing its Larger Meters and to Provide Less Water Storage.

specifications for additional water storage facilities. Bracken Water has made an application to the Commission for approval to construct additional water storage facilities in Case No. 94-211.<sup>2</sup> This case is presently under review. To allow time for review and for completion of construction, Bracken Water has requested a time extension until December 31, 1995 to comply with the requirements of Commission Regulation 807 KAR 5:066, Section 4(4).

The Commission, having reviewed the information submitted and being otherwise sufficiently advised, finds that Bracken Water is making a good faith effort toward bringing its facilities into compliance with Commission regulations and that additional time is necessary to comply with the requirements of Commission Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Bracken Water be and it hereby is granted a deviation until December 31, 1995 to comply with the provisions of 807 KAR 5:066, Section 4(4).


2. Bracken Water shall take all necessary action to bring its water storage facilities into compliance with Commission regulations prior to December 31, 1995.


---

<sup>2</sup> Case No. 94-211, The Application of Bracken County Water District #1 for a Certificate of Public Convenience and Necessity to Construct and Finance a Water Storage Tank.

Done at Frankfort, Kentucky, this 20th day of January, 1995.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director